



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

**Report of Materials and  
 Equipment Acceptance Division**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

**MEA 382-07-M**

**Manufacturer:** Wilson-Art International Inc.,  
 385 Lafleur Avenue,  
 LaSalle, Quebec H8R 3H, CANADA

**Trade Name(s):** Lamin-Art

**Product:** High pressure decorative laminate for interior-finish applications

**Pertinent Code Section(s):** 27-348

**Prescribed Test(s):** RS 5-5 (ASTM E84), Toxicity

**Laboratory:** Southwest Research Institute  
 Underwriters Laboratories, Inc.

**Test Report(s):** No. 01-6762-243-a dated October 19, 1982  
 No. 01-8818-708 dated October 1987  
 No. 016762-243 dated August 19, 1982.  
 UL letter, reference File R5457, dated November 2, 2007.

**Description:** Decorative laminates designated HPDL (fire-rated) available in the tabulated-described thicknesses, intended for use as an interior finish over non-combustible substrates. All sheets are available in lengths of 96, 120, 144 inches, and in widths of 36, 48, 60 inches, and in various colors and patterns.

Model No.	Nominal Thickness (Inches)
LFR3	0.032
LFR5	0.050

Flame Spread Rating – 10;      Smoke Developed Rating – 15

**Terms and Conditions:** The above laminate sheets, as conforming to interior finish Class "A" requirements and having the smoke developed rating as indicated above, are accepted under the following conditions:

1. Upon exposure to fire the sheets do not produce products of decomposition or combustion that are more toxic than those given off by wood or paper, when decomposing or burner under comparable conditions.
2. All shipments and deliveries of such material shall be accompanied with a certificate or label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance January 15, 2008

Examined By Simon Derphidan