

AWTA PRODUCT TESTING

A Division of Australian Wool Testing Authority Limited

Laboratory: 1st Floor, 191 Racecourse Rd, Flemington, Victoria 3031 P.O. Box 240 Nth Melbourne 3051 Tel: (03) 9371 2400 Fax: (03) 9371 2499
Website: www.awtaproducttesting.com.au Email: producttesting@awta.com.au

A.B.N. 43 006 014 106

Group Number Assessment

(in accordance with Specification A2.4 of the National Construction Code of Australia)

Number: 1602007
Issue Date: 24 February 2016

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837 - 1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

AWTA Product Testing report number: 16-000328

Date of Test: 11 February 2016

Test Sponsor

Wilsonart Australia
Unit 3B
13 – 15 Forrester Street
Kingsgrove
NSW
2008

Sponsor Product Reference: "Wilsonart Laminate"

Sponsor Product Description: High Pressure Laminate, White Face.
Nominal Composition: High Pressure Laminate, 1.2kg/m², 0.8mm thickness

Product Group Number Classification: Group 1
Average Specific Extinction Area: 10.3 m²/kg

Chris Campbell
Client Relations Manager

It should be borne in mind that the opinions expressed in this letter are based on a limited number of observations made on a single sample and may be subject to alteration if more detailed testing was to be carried out. We recommend that you have further testing conducted if the information above is critical to your decisions on this product.

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.